




Walkthrough Inspections

40 CFR 280.36





New Operation And Maintenance Requirements



- ***Periodic Walkthrough Inspections (beginning October 13, 2018)***
 - Every 30 Days
 - Check spill prevention equipment
 - Check *release detection equipment and records
 - Annually
 - Check containment sumps
 - Check hand held release detection equipment
 - Keep records of the walkthrough inspection for 1 year



* This requirement excludes checking equipment located in containment sumps. Records associated with equipment located in sumps still need to be checked every 30 days.





Questions And Additional Information

- Any Questions?
- For More Information
 - Contact: Tim Smith, 202- 564-0643, smith.timr@epa.gov
 - Visit the OUST website at: <http://www.epa.gov/ust>