

Titan Cloud

Wet Test

VOLUMETRIC TANK TIGHTNESS TEST METHOD (Underfill)

Certification	Calculated minimum detectable leak rate of 0.1 gph with PD = 99.99% and PFA = 0.0099% at 95% tank volume and the PD is greater than 97.31% at all other tank volumes.
Leak Threshold	Calculated leak threshold is 0.050 gph with PD = 95% and PFA = 5%. A tank system should not be declared tight if the test result indicates a loss or gain that equals or exceeds this threshold
Applicability	Gasoline, diesel, aviation fuel, fuel oil #4, solvents, waste oil, biodiesel blends B6-B20 meeting ASTM D7467, biodiesel B100 meeting ASTM D6751.
Tank Capacity	Maximum size of tank = 20,000 gallons.
Waiting Time	Minimum of 2 hours and 59 minutes between delivery and testing.
Test Period	Minimum of 1 hour and 7 minutes. There must be no dispensing or delivery during test.
Temperature	If a test is to be conducted following a product delivery, the delivered product should not have temperature differences greater than ± 6.5 degrees F from the product already in the tank.
Groundwater	Depth to groundwater in tank excavation backfill should be determined if possible. If groundwater is above bottom of tank or is undetermined, then two passing tests are required at different product heights or different tank pressures to achieve a 1.5 psi differential. Conducting the Leighton O'Brien Wet Test and the Leighton O'Brien Dry Test (NVTTC Ullage) in combination will achieve this result.
Calibration	Differential pressure sensor must be calibrated regularly in accordance with manufacturer's instructions.
Comments	This method was not evaluated with groundwater taken into account. Tests only portion of tank containing product. Not evaluated using manifolded tank systems. Testing can be conducted at product levels of 10 inches or greater. Evaluated in a 13,750 gallon, horizontal fiberglass tank containing diesel fuel with a diameter of 120 inches and 323 inch length.

Titan Cloud
4015 Travis Dr, Suite 211 #1787
Nashville, TN 37211
Tel: (615) 372-6000
E-mail: roi@titancloud.com
URL: <https://www.titancloud.com>

Evaluator: Ken Wilcox Associates
Tel: (816) 443-2494
Dates of Evaluation: 12/01/2016



Appearance on this list is not to be construed as an endorsement by any regulatory agency nor is it any guarantee of the performance of the method or equipment.

Equipment should be installed and operated in accordance with all applicable laws and regulations. For full details, please refer to our expanded "[DISCLAIMER](#)" page.